



CERTIFICATE

| | |
|---------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Certificate holder | Techem Energy Services GmbH Hauptstr. 89 65760 Eschborn GERMANY |
| Product | Heat cost allocators - Appliances with electrical energy supply |
| Type, Model | FHKV radio 4 / EHKV vario 4 |
| Testing basis | DIN EN 834:2013-12 Certification scheme Heat cost allocators (2014-08) |
| Mark of conformity |  |
| Registration No. | 295/15 E |
| Valid until | 2021-01-31 |
| Right of use | This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information. |

2016-02-04


Dipl.-Phys. Carlo Seiser
Certifier

ANNEX

Page 1 of 1

| | |
|------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Certificate | 295/15 E dated 2016-02-04 |
| Technical Data | Type: Compact and remote sensor version Readout of measured values: decentral Basic conditions: 50 °C Upper temperature limits stated t(max): 90 °C Compact device, 130 °C Remote sensor device Lower temperature limits stated t(min): 35 °C |
| Testing laboratory/ Inspection body | Universität Stuttgart Institut für GebäudeEnergetik Pfaffenwaldring 35 70569 Stuttgart GERMANY |
| Test report(s) | SD15 H001 TE dated 2015-06-26 SD15 H001 TE K.1 dated 2016-01-15 |

